

M J Nankivell HazTec Ltd

Mike Nankivell Director

PO Box 199 Silverdale 0944 Auckland North

p 09 426 5902 f 09 426 5903

e info@haztec.co.nz www.haztec.co.nz

Issued pursuant to Section 82 of the

Hazardous Substances and New Organisms Act 1996

This certifies that:

Service Engineers Ltd

Contact details:

**50-52 Porana Road
Takapuna
Auckland 0627
Tel 09 441 7790**

13 MAY 2013

Has met the relevant requirements for fabrication of stationary containers per the design standards / codes and maximum capacities specified below, in accordance with clauses 94 and 95 of Schedule 8 of the Hazardous Substances (Dangerous Goods and Scheduled Toxic Substances) Transfer Notice 2004.

An audit of the above named stationary container fabricator was conducted on **8 May 2013** in relation to the fabricator's documentation, library of standards, design drawings, structural checking procedures, stationary container designs, trade training qualifications, trade supervision, fabrication procedures, testing procedures, quality assurance and quality control.

Design Standards / Codes

AS 1210

AS 1692

API 650

Maximum Tank Capacities:

N/A

150,000 L

N/A

Conditions:

- 1 Unless surrendered or revoked, this certificate remains valid until the **17 May 2016** and may be renewed thereafter by an authorised test certifier, subject to the fabricator successfully completing a re-audit.
- 2 This certificate must be produced at the request of an enforcement officer appointed under the HSNO Act 1996.
- 3 The above fabricator is certified to manufacture specific approved designs of stationary containers as set out in the Stationary Container Systems Approved Design and Fabricators Register.



Date of Issue: 18 May 2013

M J Nankivell

Test Certifier Registration No 000101

